

**6<sup>TH</sup> CORRIGENDUM TO TENDER CALL NOTICE NO: 69/ 2011-12.**

For and on behalf of ODISHA POWER TRANSMISSION CORPORATION LIMITED, Chief General Manager (CPC) extends the last date of receipt & opening of tender notice No: 69/2011-12 & Tender specification No.78/2011-12 to date 17/07/2012 up to 1P.M & to be opened on date 17/07/2012 at 3.30 P.M. The interested manufacturers/authorized supplier of HTLS conductor may visit our web site <http://www.optcl.co.in>, for detail amendments to the specification.

Chief General Manager (CPC)

**Amended clauses.**

**Clause No.13 of section-III of SCC (Special condition of contract)** The delivery & completion period has been extended as follows.

**Time Schedule:**

Name of the package.	Name of the line	Delivery at owner's store	Erection, testing & commissioning
Package-I.A	132 Kv Chandaka Mancheswar ckt-I &II . ( 2X5.88 Km)	105 days from the date of placement of letter of award	135 days from the date of placement of letter of award
Package-I.B	132 Kv Tarkera – Chhend line (2X 6.16 Km)	105 days from the date of placement of letter of award	135 days from the date of placement of letter of award
Package-II.	1. 132 Kv Chandaka – Nimapara line ( 57.25 Km) 2. 132 Kv Chandaka – Ranasingpur line ( 24.25 Km)	Package -II , has been withheld. Bidders should not quote for this package.	

**1.1.9** The project scope of package-I, is split in to two packages.

I) Package-IA, 132 KV Chandaka- Mancheswar ( D/C Line, 2X 5.88 Circuit KM)

II) Package-IB, 132 Kv Tarkera- Chhend ( D/C Line, 2X 6.16 Circuit KM)

Intending bidders can either participate in package-IA, or in package-IB, or in both package-IA & package-IB.

EMD for package-IA =Rs 23.52 Lakhs.

EMD for package-IB=Rs 24.64 Lakhs

EMD for package-I A& package-IB.(Combining)=Rs 48.16 Lakhs.

In the event of an eligible bidder becoming L1 in both the packages of 1A &1B, they will be considered for award of both the packages provided they meet the combined eligibility criteria as per clause 2.1, 2.1.1 to 2.1.4 of section-I (ITB). Otherwise they will be

awarded only one package out of the two at the discretion of OPTCL considering the least cost to OPTCL.

**Outer Layer**

**For package –I.A, 132 Kv Chandaka – Mancheswar ckt-I &II .( 2X5.88 Km)**

The material of outer layer of HTLS conductor shall be of high temperature resistant aluminum/ aluminum alloy added with zirconium or any other suitable elements to electrolytic aluminum having purity not less than 99.5% and a copper content not exceeding 0.04%. Bidder shall guarantee the chemical composition in the schedule GTP and also furnish description of the manufacturing process in the bid. The tower schedule of 132 KV Chandaka-Mancheswar Circuit-I is similar to 132 KV Chandaka-Mancheswar Circuit-II.

**In case of fully annealed type (0 tampered) alluminium / alloy strands trapezoidal / Z –shaped wire shall only be accepted.**

**For Package –I.B, 132 Kv Tarkera – Chhend line (2X 6.16 Km)**

The material of outer layer of HTLS conductor shall be of high temperature resistant aluminum/ aluminum alloy added with zirconium or any other suitable elements to electrolytic aluminum having purity not less than 99.5% and a copper content not exceeding 0.04%. Bidder shall guarantee the chemical composition in the schedule GTP and also furnish description of the manufacturing process in the bid. **Annealed conductor shall not be accepted.**

Chief General Manager (CPC)