

**AMENDMENT TO TENDER NOTICE NO-33/2012-13.**

**A-**

Sl. No	Name of the Clause	Page No	Details as per Tender Specification	Amended as						
1	<b>Part-A(b) A(b). 2.6 (i)</b>	<b>52</b>	<p>The VRLA batteries and the associated chargers shall unless otherwise specified, conform to the following standards. The firms are requested to furnish the following specifications for our further reference.</p> <table border="1"> <tr> <td>i</td> <td>IS-1651/1991</td> <td>Specification for stationary cells batteries, leads acid type.</td> </tr> </table>	i	IS-1651/1991	Specification for stationary cells batteries, leads acid type.	<p>The VRLA batteries and the associated chargers shall unless otherwise specified, conform to the following standards. The firms are requested to furnish the following specifications for our further reference.</p> <table border="1"> <tr> <td>i</td> <td>IS-15549: 2005</td> <td>Specification for VRLA batteries,</td> </tr> </table>	i	IS-15549: 2005	Specification for VRLA batteries,
i	IS-1651/1991	Specification for stationary cells batteries, leads acid type.								
i	IS-15549: 2005	Specification for VRLA batteries,								
2	<b>Part-A(b) A(b). 4.12</b>	<b>56</b>	<p>A(b).4.12.<b><u>TERMINALS:-</u></b> Terminals shall be of integral lead terminal with solid copper core with <b>M6</b> threading for fastening. The junction between terminals posts and cover and between the cover and container shall be hermetically sealed.Provision shall be there for identification of +ve &amp; -ve terminals.</p>	<p>A(b).4.12.<b><u>TERMINALS:-</u></b> Terminals shall be of integral lead terminal with solid copper core with <b>M6 or higher</b> threading for fastening. The junction between terminals posts and cover and between the cover and container shall be hermetically sealed.Provision shall be there for identification of +ve &amp; -ve terminals.</p>						
3	<b>Part-A(b) A(b). 7.0</b>	<b>57</b>	<p>A(b).7.0. <b><u>CAPACITY:-</u></b> The standard Ampere-hour capacity at ten hour rate shall be 350 AH and end cell voltage of 1.80 volts /cells.</p>	<p>A(b).7.0. <b><u>CAPACITY:-</u></b> The standard Ampere-hour capacity at ten hour rate shall be 350 AH and end cell voltage of 1.75 volts /cells.</p>						
4	<b>GTCC-19- (b)[i]</b>	<b>20</b>	<p>The successful bidder is required to submit Security Bank Guarantee for 100% [hundred percent] of the total buy back cost of the old battery sets from any nationalized/scheduled bank having a place of business at Bhubaneswar, to the office of Chief General Manager [Central Procurement Cell] OPTCL</p>	<p>The successful bidder is required to submit Security Bank Guarantee for 100% [hundred percent] of the total buy back cost of the old battery sets from any nationalized/scheduled bank having a place of business at Bhubaneswar, to the office of Senior General Manager [Central Procurement Cell] OPTCL</p>						

		<p>within 15 days from the date of issue of the purchase order,. The BG shall be executed on non judicial stamp paper worth of Rs.29.00 [Rupees twenty nine] only or as per the prevalent rules, valid for a period till lifting of old batteries , failing which the supply order will be liable for cancellation without any further written notices. The BG should be accompanied by a confirmation letter from the concerned bank and should have provision for encashment at Bhubaneswar, before the Bank Guarantee is accepted and all concerned intimated. The B.G should be revalidated as and when intimated to you to cover the entire required period.</p>	<p>within 15 days from the date of issue of the purchase order,. The BG shall be executed on non judicial stamp paper worth of Rs.29.00 [Rupees twenty nine] only or as per the prevalent rules, valid for a period till lifting of old batteries , failing which the supply order will be liable for cancellation without any further written notices. The BG should be accompanied by a confirmation letter from the concerned bank and should have provision for encashment at Bhubaneswar, before the Bank Guarantee is accepted and all concerned intimated. The B.G should be revalidated as and when intimated to you to cover the entire required period. In absence of security B.G for buy-back of old battery set ,the total cost of buy back of old battery will be deducted from the supply bill of New Battery set.If the firm fails to lift the old battery set within 90 days of supply and commissioning of new battery set ,their claim on the old battery set will be forfeited and no money will be paid to them.</p>
--	--	---	---

**B-**

**The date of sale of tender paper is extended upto 02.01.2013 (1.00 PM).**

**The last date of submission of tender is extended upto 02.01.2013 (1.00 PM).**

**The date of opening of tender is extended upto 02.01.2013 (4.00 PM).**

Senior General Manager (CPC)