

**CORRIGENDUM NO. 1 TO TENDER SPECIFICATION NO. SR.G.M.-CPC-TELE.COM-PLC&SCADA-14/2012-13**

SL. NO.	TITLE OF ISSUE	CLAUSE REFERENCE OF TENDER SPECI	CLARIFICATIONS /MODIFICATIONS BY OPTCL.
1	2	3	4
1(a)	Payment terms twords supply of equipment / Materials	Page-18, Clause-21(A) of Tender Specification.	Payment term shall be as per OPTCL Tender Specification.
(b)	Payment terms twords erection, testing & commissioning	Page-19, Clause-21(B) of Tender Specification.	Payment term shall be as per OPTCL Tender Specification.
2	Guarantee	Page-17, Clause-18 of Tender Specification.	Guarantee Clause as per Tender Specification.
3(a)	Penalty for delay in completion of the contract	Page-19, Clause-22 of Tender Specification.	Penlaty as per Tender Specification.
(b)	Penalty for delay in complition of work in comprehensive in AMC	Page-64, Clause-V, Part-III (A) & Page-67, Section-VI, Part-III (A) of Tender Specification.	Tender Specification, Sec-V, Pt.III,(A) & Section-VI, Part-III (A) for comprehensive AMC upper limit of penalty is 10% if delay is within 30 days and up to 20% if delay exceeds one month.
4	Rejection of materials	Page-14, Clause-VI of Tender Specification.	Rejection of material as per Tender Specification.
5	Qualifying requirement	Page-22, Para-5:- The bidder shall have supplied 100 nos.; of equipments to different utilities in India in last five years and performance certificates of at least 50 nos. from different utilities shall be submitted with the bid.	The Bidder should have supplied minimum 30 nos. of equipments to different utilities in India in last five years and performance certificates from the utilities are to be furnished, atleast one of such certificates should be from Govt/Govt undertaking organisation.
6	Outright rejection of Tender.	Page-23, Clause-34 (VIII) of Tender Specification.	The equipments sholuld be type tested at Electronics Regional Test Laboratory (North), New Delhi/ EMV Rhein-Neckar GmnH, Dornierstr. 5a, 68519 Viernheim/ LCIE, France / Deutscher Akkreditier Rat (DAR).or any Govt. of India approved Laborarory.
7	Civil Works	Earlier not specified.	Civil works are in the OPTCL scope.
8	Price variation..	Page-40, Clause-1 of Tender Specification.	Price is to be kept firm.
9	Substation wise RTU LO count details & other particulars on RTU.	Earlier not specified.	RTU point count & location details are available at Annexure-'B' to Annexure-'S'
10	Voltage level (KV)_ & inter linking stations etc.	Earlier not specified.	The line diagrams architecture and connection details are available at Annexure T1 to Annexure-T-21. The voltage level (KV & interlinking station are given at Annexure-'A'