

**ORISSA POWER TRANSMISSION CORPORATION LIMITED**

**Construction of 2x40 MVA 132/33 KV Sub-Station at CDA,CUTTACK along with 132 KV D.C Transmission Line(LILO on existing 132 KV line from Chaudwar to Bidanasi) & Associated System**

**BID DOCUMENT No.: Sr. G.M-CPC- Tender-132 KV-CDA-CUTTACK-10-01/2012-13**

**NOTICE INVITING TENDER-NIT NO. 10 /2012-13**

**(F&I For Supply of Equipment/Materials Price Break-up against CDA,CUTTACK PACKAGE)**

<b>PART-I, SCHEDULE-2C (FOR SUBSTATION)</b>					
<b>S. No.</b>	<b>DESCRIPTION OF ITEMS</b>	<b>Erection &amp; Civil Works charges IN INR</b>			
		<b>UNITS</b>	<b>Quantity for: Construction of 2x40 MVA, 132/33 KV Sub-Station at CDA,CUTTACK</b>	<b>Unit Erection Rate</b>	<b>Total Erection Price</b>
<b>1</b>	<b>2</b>	<b>3</b>	<b>4</b>	<b>5</b>	<b>6=4X5</b>
<b>A</b>	<b>ELECTRICAL WORKS</b>				
<b>1</b>	145 KV,800-400-200 A,31.5 KA,4CORE SINGLE PHASE CURRENT TRANSFORMER	NOS	15		
<b>2</b>	145 KV,1250A,31.5KA,ISOLATORS				
<b>2.1</b>	S/I WITH OUT EARTH SWITCH	NOS	8		
<b>2.2</b>	D/I WITH SINGLE EARTH SWITCH	NOS	2		
<b>2.3</b>	D/I WITHOUT EARTH SWITCH	NOS	2		
<b>3</b>	145 KV,6600pF,3CORE,SINGLE PHASE CAPACITOR VOLTAGE TRANSFORMER	NOS	6		
<b>4</b>	120 KV METAL OXIDE SURGE ARRESTOR, 10 KA, Class III	NOS	12		
<b>5</b>	145 KV ,2 CORE,SINGLE PHASE,IVT	NOS	3		
<b>6</b>	132 KV Bus Post Insulators	NOS	18		
<b>7</b>	145KV,3150A,40KA,SF6,CIRCUIT BREAKER WITH SUPPORTING STRUCTURE	NOS	5		
<b>8</b>	36 KV,800-400-200,25KA,3CORE SINGLE PHASE CURRENT TRANSFORMER	NOS	24		
<b>9</b>	36 KV CLASS NCT FOR POWER TRANSFORMER REF PROTECTION (RATIO 800-400-200 A) & HAVING TWO CORE (PS CLASS) (IN EACH POWER TRANSFORMER 132 KV SIDE: 1 NO, & 33 KV SIDE:1 NO)	NOS	4		

<b>PART-I, SCHEDULE-2C (FOR SUBSTATION)</b>					
<b>S. No.</b>	<b>DESCRIPTION OF ITEMS</b>	<b>Erection &amp; Civil Works charges IN INR</b>			
		<b>UNITS</b>	<b>Quantity for: Construction of 2x40 MVA, 132/33 KV Sub-Station at CDA,CUTTACK</b>	<b>Unit Erection Rate</b>	<b>Total Erection Price</b>
<b>1</b>	<b>2</b>	<b>3</b>	<b>4</b>	<b>5</b>	<b>6=4X5</b>
<b>10</b>	<b>36 KV,800A,25KA,ISOLATORS</b>				
<b>10.1</b>	S/I WITH OUT EARTH SWITCH	NOS	9		
<b>10.2</b>	D/I WITH SINGLE EARTH SWITCH	NOS	5		
<b>10.3</b>	D/I WITHOUT EARTH SWITCH	NOS	2		
<b>10.4</b>	S/I WITH BEAM MOUNTED	NOS	2		
<b>11</b>	30 KV, METAL OXIDE SURGE ARRESTOR, 10KA, class II	NOS	27		
<b>12</b>	36 KV ,2 CORE,SINGLE PHASE,IVT	NOS	3		
<b>13</b>	36KV,1250A,25KA,VACUUM CIRCUIT BREAKER WITH SUPPORTING STRUCTURE	NOS	8		
<b>14</b>	33 KV Bus Post Insulators	NOS	28		
<b>15</b>	<b>BUS BAR &amp; CIRCUIT MATERIALS</b>				
<b>15.1</b>	TENSION & SUSPENSION ANTI FOG TYPE INSULATOR STRING				
<b>15.1.1</b>	<b>120 KN INSULATOR STRINGS for Double tension Twin Moose conductor (TENSION)-132 KV</b>	<b>SET</b>	<b>54</b>		
<b>15.1.2</b>	<b>120 KN INSULATOR STRINGS for single tension Single Moose conductor (TENSION)-132 KV</b>	<b>SET</b>	<b>66</b>		
<b>15.1.3</b>	<b>120 KN INSULATOR STRINGS for Double Tension Twin Moose conductor ( TENSION)-33 KV</b>	<b>SET</b>	<b>18</b>		
<b>15.1.4</b>	<b>120 KN INSULATOR STRINGS for Single tension Single Moose conductor (TENSION)-33 KV</b>	<b>SET</b>	<b>42</b>		
<b>15.1.5</b>	90 kN ANTIFOG INSULATOR STRINGS for Double/ Single Moose cond ( SUSPENSION)-132 KV	SET	24		
<b>15.1.6</b>	90 kN ANTIFOG INSULATOR STRINGS for Double/ Single Moose cond (SUSPENSION)-33 KV	SET	15		
<b>15.2</b>	ACSR MOOSE CONDUCTOR	LOT	1		

<b>PART-I, SCHEDULE-2C (FOR SUBSTATION)</b>					
<b>S. No.</b>	<b>DESCRIPTION OF ITEMS</b>	<b>Erection &amp; Civil Works charges IN INR</b>			
		<b>UNITS</b>	<b>Quantity for: Construction of 2x40 MVA, 132/33 KV Sub-Station at CDA,CUTTACK</b>	<b>Unit Erection Rate</b>	<b>Total Erection Price</b>
<b>1</b>	<b>2</b>	<b>3</b>	<b>4</b>	<b>5</b>	<b>6=4X5</b>
<b>15.3</b>	HARDWARES & FITTINGS/SPACERS/CLAMP & CONNECTORS	LOT	1		
<b>15.4</b>	EARTH WIRES & IT'S HARDWARES & FITTING	LOT	1		
<b>15.5</b>	SUBSTATION EARTHING SYSTEMS				
<b>15.5.1</b>	EARTHING CONDUCTOR FOR BURRIAL : 75X10 mm GI Earth Flat for laying ( <i>spacing maximum 5m</i> ) (Substation earth mat): Design, engineering, supply (except the MS Rods, only erection) inclusive of corrosion protection measures if any,laying of earth mat conductors of size 75X10 mm GI Flat as per the approval of Engineer in charge, excavation, welding/jointing of ground conductors along with risers (a) up to Finished level from the mat size 75X10 mm GI Flat with back filling and good compaction,The spacing between the earth conductor not more than 5 mtrs (both way) and to be buried at depth of 700 mm from the finished ground level as per the practice and as per specification.	LOT	1		
<b>15.5.2</b>	EARTHING CONDUCTOR: 50x6 mm <b>GI Flat</b> for Raiser from the burial earth mat to equipment,structure including proper welding, bending and anti corrosive painting etc from the finished ground level to the top of the structure and equipment shall be with 50X6 mm GI Flats, as per approved drawing and specification.	LOT	1		
<b>15.5.3</b>	EARTHING DEVICE & ASSOCIATED ACCESSORIES (50 mm heavy duty GI PERFORATED PIPE 3 mtrs long for treated earth pit): perforated 50 mm Heavy duty GI pipes for treated earth pits (with details of treatment as per IS) including, excavation,supply of Bentonate powder and other materials for the treated earth pit as per standard practice and as per specification.	LOT	1		
<b>15.5.4</b>	EARTHING DEVICE & ASSOCIATED ACCESSORIES 40mm MS rod 3 mtrs long for non treated earth pit)	LOT	1		
<b>15.5.5</b>	G.I Cable Trays including support GI angle suitable for different sections i.e. Section:1-1,2-2,3-3 & 4-4 along with its accessories as per TS.	LOT	1		
<b>15.6</b>	SUB STATION SWITCHYARD BMK,AC CONSOLE & OTHER MARSHALLING BOXES				
<b>15.6.1</b>	BAY MARSHALLING KIOSK ( <i>03 Nos 132 kv bay &amp; 04 Nos 33 KV bay</i> )	NOS	7		
<b>15.6.2</b>	SWITCH YARD AC CONSOLE FOR LIGHTING ( <i>01 Nos 132 kv bay &amp; 01 No in 33KV bay</i> )	NOS	2		

<b>PART-I, SCHEDULE-2C (FOR SUBSTATION)</b>					
<b>S. No.</b>	<b>DESCRIPTION OF ITEMS</b>	<b>Erection &amp; Civil Works charges IN INR</b>			
		<b>UNITS</b>	<b>Quantity for: Construction of 2x40 MVA, 132/33 KV Sub-Station at CDA,CUTTACK</b>	<b>Unit Erection Rate</b>	<b>Total Erection Price</b>
<b>1</b>	<b>2</b>	<b>3</b>	<b>4</b>	<b>5</b>	<b>6=4X5</b>
15.6.3	SWITCH YARD RECEPTACLE BOARD FOR TFR OIL FILTERATION ( 1 No near 132/33 KV power Transformer)	NOS	1		
15.6.4	SWITCH YARD RECEPTACLE BOARD FOR WELDING & OTHER EMERGENCY (01 nos each on 132 & 33 kV bay )	NOS	2		
16	<b>SWITCH YARD STRUCTURES (LATTICE TYPE) FOR 220/132/33 KV CLASS INCLUDING FOUNDATION BOLTS &amp; NUTS.</b>				
16.1	<b>DIFFERENT TYPES OF COLUMNS WITH DETAILS</b>				
16.1.1	T1S - 132 KV(NOMINAL UNIT WT- 1.2 MT)	NOS	24		
16.1.2	T4S - 132KV (NOMINAL UNIT WT- 0.95 MT)	NOS	6		
16.1.3	T8S - 33KV(NOMINAL UNIT WT- 0.8 MT)	NOS	9		
16.1.4	T9S - 33KV(NOMINAL UNIT WT- 0.6 MT)	NOS	11		
16.2	<b>DIFFERENT TYPE OF BEAMS WITH DETAILS</b>				
16.2.1	G1 - 132 KV(NOMINAL UNIT WT- 0.62 MT)	NOS	22		
16.2.2	G1X - 132 KV (NOMINAL UNIT WT- 1.4 MT)	NOS	2		
16.2.3	G2 - 132 KV(NOMINAL UNIT WT- 0.91 MT)	NOS	4		
16.2.4	G1,2 - 132 KV(Each two beams of G1 type) (NOMINAL UNIT WT- 1.25 MT)	NOS	0		
16.2.5	G6 - 33KV (NOMINAL UNIT WT- 0.53 MT)	NOS	9		
16.2.6	G4 - 33KV(NOMINAL UNIT WT- 0.4 MT)	NOS	2		
16.2.7	G4X - 33KV (NOMINAL UNIT WT- 0.4 MT)	NOS	3		
16.3	<b>TOTAL WEIGHT OF COLUMN &amp; BEAM</b>	MT	76		
16.4	<b>SUPPORT STRUCTURES (LATTICE/PIPE TYPE) FOR ALL 132 KV &amp; 33KV EQUIPMENTS</b>				
16.4.1	ISOLATORS-132KV	<b>NOS</b>	12		

<b>PART-I, SCHEDULE-2C (FOR SUBSTATION)</b>					
<b>S. No.</b>	<b>DESCRIPTION OF ITEMS</b>	<b>Erection &amp; Civil Works charges IN INR</b>			
	<b>ERECTION, TESTING &amp; COMMISSIONING INCLUDING CIVIL WORKS OF FOLLOWING EQUIPMENTS ALONG WITH CIVIL WORKS (As per Technical Specification)</b>	<b>UNITS</b>	<b>Quantity for: Construction of 2x40 MVA, 132/33 KV Sub-Station at CDA, CUTTACK</b>	<b>Unit Erection Rate</b>	<b>Total Erection Price</b>
<b>1</b>	<b>2</b>	<b>3</b>	<b>4</b>	<b>5</b>	<b>6=4X5</b>
16.4.2	ISOLATORS-33 KV	NOS	18		
16.4.3	CTS-132 KV	NOS	15		
16.4.4	CTS-33 KV	NOS	24		
16.4.5	CVTS-132 KV	NOS	6		
16.4.6	IVTS-132 KV	NOS	3		
16.4.7	IVTS-33 KV	NOS	3		
16.4.8	Surge Arrester-132 kV	NOS	12		
16.4.9	Surge Arrester-33 kV	NOS	27		
16.4.10	Wave Trap-132 KV	NOS	4		
16.4.11	BPI-132 KV	NOS	18		
16.4.12	BPI-33 KV	NOS	28		
16.4.13	NCTS	NOS	4		
16.5	<b>TOTAL WEIGHT OF EQUIPMENT STRUCTURE</b>	MT	50		
16.6	<b>Total weight of GI Nuts and bolts for the above structures</b>	MT	12		
17	<b>GENERAL EQUIPMENT &amp; SUBSTATION ACCESSORIES</b>				
17.1	<b>POWER CABLES, 1.1KV, XLPE, ARMOURED, ALUMINIUM CONDUCTOR (As per Specification)</b>				
17.1.1	3.5 CX300 mm <sup>2</sup>	LOT	1		
17.1.2	3.5 CX185 mm <sup>2</sup>	LOT	1		
17.1.3	3.5 CX120 mm <sup>2</sup>	LOT	1		
17.1.4	3.5 CX70 mm <sup>2</sup>	LOT	1		
17.1.5	3.5 CX35 mm <sup>2</sup>	LOT	1		

<b>PART-I, SCHEDULE-2C (FOR SUBSTATION)</b>					
<b>S. No.</b>	<b>DESCRIPTION OF ITEMS</b>	<b>Erection &amp; Civil Works charges IN INR</b>			
		<b>UNITS</b>	<b>Quantity for: Construction of 2x40 MVA, 132/33 KV Sub-Station at CDA,CUTTACK</b>	<b>Unit Erection Rate</b>	<b>Total Erection Price</b>
<b>1</b>	<b>2</b>	<b>3</b>	<b>4</b>	<b>5</b>	<b>6=4X5</b>
17.1.6	4 CX 16 mm <sup>2</sup>	LOT	1		
17.1.7	4 CX 6 mm <sup>2</sup>	LOT	1		
17.1.8	2CX 6 mm <sup>2</sup>	LOT	1		
17.2	<b>CONTROL CABLES,1.1 KV, PVC,STRANDED COPPER(As per specification)</b>				
17.2.1	4 CX 2.5 mm <sup>2</sup>	LOT	1		
17.2.2	5 CX 2.5 mm <sup>2</sup>	LOT	1		
17.2.3	7CX 2.5 mm <sup>2</sup>	LOT	1		
17.2.4	10 CX 2.5 mm <sup>2</sup>	LOT	1		
17.2.5	12 CX 2.5 mm <sup>2</sup>	LOT	1		
17.2.6	16 CX 2.5 mm <sup>2</sup>	LOT	1		
17.2.7	19 CX 2.5 mm <sup>2</sup>	LOT	1		
17.2.8	1CX 120 mm <sup>2</sup> BAT TO BAT CHARGER & CHARGER TO DCDB	LOT	1		
18	<b>ACCESSORIES FOR PLCC SYSTEM AS PER TECHNICAL SPECIFICATION</b>				
18.1	132 kV Line Trap for Pedestal mounting with complete accessories :800A, 0.5 mH, (90-500kHz),Isc=40kA compatible to IEC 353 specifications	NOS	4		
18.2	LINE MATCHING UNIT & LINE MATCHING DISTRIBUTION UNIT	SET	2		
18.3	12.5 mm OD armoured Co-axial Cable; Impedance: 75 ohms, Insulation Resistance: 100 Meg Ohms Dielectric strength: 5 kV, Signal attenuation: 6 dB/KM (Max) at 500 kHz	MTRS	1000		
18.4	EPAX standard complied to ITU-T, G-711,G-712,Q507,Q-517 capacity 16lines/Trunks, specification transducers and interfacing cards for Analog input and Digital output (Optional)	NO	1		
18.5	25 PAIR ARMOURED JELLY FILLED CABLE	MTRS	1000		
18.6	10 PAIR ARMOURED TELEPHONE CABLES	MTRS	500		
18.7	4 PAIR NON ARMOURED TELEPHONE CABLES	MTRS	300		

<b>PART-I, SCHEDULE-2C (FOR SUBSTATION)</b>					
<b>S. No.</b>	<b>DESCRIPTION OF ITEMS</b>	<b>Erection &amp; Civil Works charges IN INR</b>			
		<b>UNITS</b>	<b>Quantity for: Construction of 2x40 MVA, 132/33 KV Sub-Station at CDA,CUTTACK</b>	<b>Unit Erection Rate</b>	<b>Total Erection Price</b>
<b>1</b>	<b>2</b>	<b>3</b>	<b>4</b>	<b>5</b>	<b>6=4X5</b>
18.8	4 WIRE TELEPHONE SET	NO	4		
18.9	2 WIRE TELEPHONE SET	NO	20		
18.10	FAX MACHINE	NO	1		
18.11	PLANTE TYPE BATTERY 350 AH(FOR 48 V)	SET	2		
18.12	BATTERY CHARGER FOR 48 V, 350 AH 70 AMP FLOAT CUM BOOST CHARGER	SET	1		
18.13	48 V DCDB	SET	1		
19	<b>ERECTION OF STATION TRANSFORMER &amp; OTHER MATERIALS FOR MEETING THE AUXILIARY SUPPLY OF THE SUB-STATION AS PER TECHNICAL SPECIFICATION</b>				
19.1	STATION TRANSFORMER 33KV/433V,315 KVA (AS PER SPECIFICATION)	NOS	2		
19.2	33 KV AB SWITCH IN 33 KV SIDE(400AMP),HG FUSE, DP STRUCTURE(preferably by using 200X100 mm RS Joist),ANGLE FOR BRACING OF DP STRUCTURE,POWER CABLES, CHANEL, FOR ERECTION OF TRANSFORMER INCLUDING INSULATORS, CONDUCTOR, CLAMPS & CONNECTOR, JUMPERING AND OTHER ACCESSORIES FOR COMMISSIONING OF THE STN TRANSFORMER.IT INCLUDES LT OUT DOOR KIOSK MADE OUT OF 14 SWG GI MARSH-ALLING BOX OR BETTER , HAVING CABLE TERMINATING FACILITY FOR INCOMING & OUT GOING TO THE BOX. THE RATING OF THE BUS BAR, TERMINAL BOX & STUDS TO BE USED SHALL HAVE CONTINEOUS RATING OF 1000 AMP. MARSHALLING BOXES ARE TO BE INSTALLED NEAR TO THE AUXILIARY STATION TRANSFORMERS.	SETS	2		
20	<b>SUB STATION LIGHTING (AS PER SPECIFICATION AND APPROVED DRAWINGS )(Switch yard and other street area)</b>				
20.1	<b>SUB-STATION SWITCH YARD LIGHTING,IT INCLUDES SUPPLY OF FIXTURES &amp; LAMPS (LED) of reputed make (Philips/CGL/Bajaj) with switch gear,GI Conduit etc.(Lighting fixtures are to be fixed rigidly on the Column at a suitable height so that the required lux can be maintained).</b>	LOT	1		

<b>PART-I, SCHEDULE-2C (FOR SUBSTATION)</b>					
<b>S. No.</b>	<b>DESCRIPTION OF ITEMS</b>	<b>Erection &amp; Civil Works charges IN INR</b>			
		<b>UNITS</b>	<b>Quantity for: Construction of 2x40 MVA, 132/33 KV Sub-Station at CDA,CUTTACK</b>	<b>Unit Erection Rate</b>	<b>Total Erection Price</b>
<b>1</b>	<b>2</b>	<b>3</b>	<b>4</b>	<b>5</b>	<b>6=4X5</b>
20.1	STREET LIGHTING, IT INCLUDES SUPPLY OF GI TUBULAR POLE, WITH LED LIGHTING FIXTURES WITH LAMPS of reputed make (Philips/CGL/Bajaj)(TO BE PROVIDED IN THE SWITCH YARD, ALONG THE ROADS (APPROACH INSIDE YARD AND OTHER ROADS).	LOT	1		
20.2	<p><b>ELECTRICAL SUPPLY TO STREET LIGHTING, COLONY QUARTERS:-</b></p> <p>&gt; 1 NO. OUTDOOR KIOSK FOR STREET LIGHTING PURPOSE HAVING 2 NOS 200 AMP SWITCH FUSE UNITS AND , 6 NOS.OUT LETS OF 32 AMP MCB FOR STREET LIGHTING. (XLPE CABLES(3.5 CORE 120 SQMM) FROM MAIN ACDB FROM CONTROL ROOM TO THE OUT DOOR KIOSK. XLPE CABLE OF 4C X 16 SQMM FROM OUTDOOR KIOSK TO THE STREET LIGHT POLES AND 4CX6 SQMM FROM POLE TO POLE AND 2CX6 SQMM FROM POLE TO LIGHTING FIXTURES.)</p> <p>&gt; 1 NO. OUTDOOR KIOSK FOR COLONY SUPPLY PURPOSE HAVING 2 NOS. 200 A SWITCH FUSE UNITS, 6 NOS.OUT LETS OF 32 AMP MCB FOR COLONY QUARTES.( XLPE CABLES(3.5 CORE 120 SQM) FROM MAIN ACDB FROM CONTROL ROOM TO THE OUT DOOR KIOSK. 4CX16 SQMM FROM KIOSK TO EACH QUARTER. PROVISION OF CABLE(2C/4C-6 SQM) FROM THE OUT DOOR KIOSK INSTALLED NEAR THE QUARTER TO THE RESPECTIVE QUARTERS UP TO THE SWITCH FUSE UNIT PROVIDED INSIDE THE QUARTERS. INDIVIDUAL CABLES FOR INDIVIDUAL QUARTERS. IT ALSO INCLUDES PROPER EARTHING OF THE QUARTER AS PER THE STANDARD PRACTICE AND SPECIFICATION.)</p> <p>&gt; ALL THE STREET LIGHT POLE SHALL BE OF GI TUBULAR POLE AND PROVISION OF A GI JUNCTION BOX WITH SUITABLE COVERS AT A HEIGHT OF 1 METRE FROM THE GROUND. (LT UNDER GROUND POWER CABLES OF 4CX6/16 SQMM SHALL BE CONNECTED TO THE JUNCTION BOX.) THE JUNCTION BOX SHALL HAVE PROVISION OF FUSES, BUSES, CONNECTORS FOR CABLE IN AND OUT. THIS INCLUDES SUPPLY OF ALL MATERIALS(EXCEPT CABLES) AS PER APPROVED DRAWING AND SPECIFICATION TO COMPLETE THE STREET LIGHTING SYSTEM. PROPER EARTHING AS PER STANDARD PRACTICE FOR STRRET LIGHT POLES AND OUTDOOR KIOSKS ARE ALSO INCLUDED IN THE SCOPE OF WORKS. THE STREET LIGHT SHALL BE OF LED LAMP FITTINGS INCLUDING LAMPS.</p> <p>(* REMARKS : FOR SUPPLY OF ALL THE CABLES AS INDICATED ARE COVERED IN THE CABLE ITEMS AS INDICATED ABOVE AT 28.1)</p>	LOT	1		



<b>PART-I, SCHEDULE-2C (FOR SUBSTATION)</b>					
<b>S. No.</b>	<b>DESCRIPTION OF ITEMS</b>	<b>Erection &amp; Civil Works charges IN INR</b>			
		<b>UNITS</b>	<b>Quantity for: Construction of 2x40 MVA, 132/33 KV Sub-Station at CDA,CUTTACK</b>	<b>Unit Erection Rate</b>	<b>Total Erection Price</b>
<b>1</b>	<b>2</b>	<b>3</b>	<b>4</b>	<b>5</b>	<b>6=4X5</b>
21	2 TR CAPACITY SPLIT AIR CONDITIONING UNITS WITH REMOTE CONTROL FACILITY: INCLUDING SUPPLY OF AIR CONDITIONERS,VOLTAGE STABILISER,CONTROL BOXES ETC FOR COMPLETING THE A.C SCHEME. (AS PER SPECIFICATION ) FOR CONTROL ROOM, CARRIER ROOM & CONFERENCE ROOM.(* <b>SUPPLY OF CABLES ARE COVERED IN CABLE ITEMS AS INDICATED ABOVE AT 28.1</b> )	LOT	1		
22	<b>FIRE FIGHTING SYSTEM(PORTABLE AND WHEEL MOUNTED SETS FOR CONTROL ROOM,EQUIPMENT LIKE TRANSFORMER AND OTHER AREAS AS PER TECH SPEC(REFER TS-INST TO BIDDER BEFORE DESIGN-SL NO 16-ANNEXURE - I)</b>				
22.1	FOAM TYPE-9 LTRS	NOS	4		
22.2	DRY CHEMICAL POWDER(TROLLEY MOUNTED)- 22.5 KGS	NOS	4		
22.3	DRY POWDER TYPE - 5 KGS	NOS	4		
22.4	CO <sub>2</sub> - 4.5 KGS	NOS	10		
22.5	CO <sub>2</sub> - 9 KGS	NOS	10		
22.6	CO <sub>2</sub> (TROLLY MOUNTED)- 22.5 KGS	NOS	4		
22.7	FIRE BUCKET (6 NOS IN EACH STAND) WITH STAND	SET	5		
23	<b>PROTECTION,CONTROL METERING, EVENT LOGGER,BUS BAR PROT N PAN,COMM PAN, RELAY TOOL KITS AS PER TECH SPEC</b>				
23.1	TIME SYNCH EQUIPMENT	NOS	1		
23.2	<b>132 KV SIDE</b>				
23.2.1	FEEDER CONTROL PANEL(GPF-1M)	NOS	2		
23.2.2	TRANSFORMER CONTROL PANEL(CPL-1M)(02 NOS FOR 132 KV SIDE OF 132/33 KV POWER TRANSFORMER)	NOS	2		
23.2.3	BUSCOUPLER CONTROL PANEL (CPB-1M)	NOS	1		
23.2.4	FEEDER RELAY PANEL(RPF-1M)	NOS	2		
23.2.5	TRANSFORMER RELAY PANEL(CPL-1M)(02 NOS FOR 132 KV SIDE OF 132/33 KV POWER TRANSFORMER)	NOS	2		

<b>PART-I, SCHEDULE-2C (FOR SUBSTATION)</b>					
<b>S. No.</b>	<b>DESCRIPTION OF ITEMS</b>	<b>Erection &amp; Civil Works charges IN INR</b>			
	<b>ERECTION, TESTING &amp; COMMISSIONING INCLUDING CIVIL WORKS OF FOLLOWING EQUIPMENTS ALONG WITH CIVIL WORKS (As per Technical Specification)</b>	<b>UNITS</b>	<b>Quantity for: Construction of 2x40 MVA, 132/33 KV Sub-Station at CDA, CUTTACK</b>	<b>Unit Erection Rate</b>	<b>Total Erection Price</b>
<b>1</b>	<b>2</b>	<b>3</b>	<b>4</b>	<b>5</b>	<b>6=4X5</b>
23.2.6	BUSCOUPLER RELAY PANEL (RPB-1M)	NOS	1		
23.2.7	COMMON PANEL (KP-1)	NOS	1		
23.3	<b>33 KV SIDE</b>				
23.3.1	FEEDER CONTROL & RELAY PANEL(CPF/RPF-0M)	NOS	5		
23.3.2	TRANSFORMER CONTROL & RELAY PANEL(CPL/RPL-0M)	NOS	2		
23.3.3	BUSCOUPLER CONTROL & RELAY PANEL (CPB/RPB-0M)	NOS	1		
24	<b>AC &amp; DC SYSTEM</b>				
24.1	<b>AC SYSTEM</b>				
24.1.1	MAIN AC DB,(HAVING 800 A,50KA,DRAWOUT TYPE ACB WITH 3 O/C,E/F,U/V RELAYING FACILITY INDOOR TYPE AS PER SPECIFICATION.(MAIN DB-1,MAIN DB-2 WITH B/C)	SET	1		
24.1.2	ACDB (HAVING 400A MCCB) AS PER SPECIFICATION (AC DB-1,AC DB-2 WITH B/C)	SET	1		
24.1.3	MAIN LIGHTING DISTRIBUTION BOARD (HAVING 250A MCCB AS INCOMER)AS PER SPECIFICATION (WITH DB-1,DB-2 & B/C)	SET	1		
24.1.4	INDOOR LIGHTING DISTRIBUTION BOARD AS PER SPECIFICATION. (WITH DB-1,DB-2 & B/C)	SET	1		
24.1.5	EMERGENCY LIGHTING DISTRIBUTION BOARD	SET	1		
24.1.6	INDOOR RECEPTACLE BOARD	SET	1		
24.2	<b>DC SYSTEM</b>				
24.2.1	220 V DC BOARD (HAVING 100A DC MCCB AS INCOMER, E/F (EARTH LEAKAGE), UNDER & OVER VOLTAGE AS PER SPECIFICATION (DC DB-1,DC DB-2 & B/C)	SET	1		
24.2.2	220 V DC EMERGENCY DISTRIBUTION BOARD	SET	1		
24.2.3	BATTERY (350 AH PLANTE TYPE) FOR 220 V DC	SET	2		
24.2.4	BATTERY CHARGER FOR 220 V, 350 AH BATTERY (FLOAT AND FLOAT CUM BOOST)	SET	2		
25	DISTLED WATER PLANT OF 10 LTR/HR FOR BATTERY BANKS	SET	1		

<b>PART-I, SCHEDULE-2C (FOR SUBSTATION)</b>					
<b>S. No.</b>	<b>DESCRIPTION OF ITEMS</b>	<b>Erection &amp; Civil Works charges IN INR</b>			
		<b>UNITS</b>	<b>Quantity for: Construction of 2x40 MVA, 132/33 KV Sub-Station at CDA,CUTTACK</b>	<b>Unit Erection Rate</b>	<b>Total Erection Price</b>
<b>1</b>	<b>2</b>	<b>3</b>	<b>4</b>	<b>5</b>	<b>6=4X5</b>
26	WALKIE TALKIE SET	SET /PAIR	2		
27	PORTABLE ALUMINIUM LADDER EXTENDABLE TYPE OF ADEQUATE HEIGHT TO BE USED FOR MAINTENANCE OF EQUIPMENT INSIDE SWITCH YARD.	NOS	2		
28	PEDESTAL MOUNTED WHEEL FITTED DERRICK FOR LIFTING/ LOWERING OF MATERIALS UP TO 1.5 TON CAPACITY.	SET	1		
29	POWER WINCH NEAR STORE SHED FOR HANDLING MATERIALS UPTO 5 TON CAPACITY.	SET	1		
30	WATER COOLER WITH WATER PURIFIER SYSTEM	NOS	1		
31	MAINTENANCE TESTING EQUIPMENT (AS PER <b>ANNEXURE - I</b> ,INDICATED IN TS-TIMK-SCHEDULE OF REQUIREMENTS OF MAINTENANCE EQUIPMENT)	LOT	1		
32	OTHER TOOLS AND PLANTS (T&P's) REQUIREMENT (AS PER <b>ANNEXURE - II</b> ,INDICATED IN TS-TIMK-SCHEDULE OF REQUI-REMENTS OTHER T&P's)	LOT	1		
33	OFFICE FURNITURE (AS PER <b>ANNEXURE - III</b> ,INDICATED IN TS-TIMK-SCHEDULE OF REQUIREMENTS OFFICE FURNITURE)>PLACING IN CONTROL ROOM,CONFERENCE ROOM,OFFICE ROOMS,LIBRARY,TESTING LAB,etc.	LOT	1		
34	BEST QUALITY &APPROVED MAKE RUBBER MAT TO BE KEPT INFRONT OF ALL PANELS,BOARDS ETC.	LOT	1		

PART-I, SCHEDULE-2C (FOR SUBSTATION)					
S. No.	DESCRIPTION OF ITEMS	Erection & Civil Works charges IN INR			
	ERECTION, TESTING & COMMISSIONING INCLUDING CIVIL WORKS OF FOLLOWING EQUIPMENTS ALONG WITH CIVIL WORKS (As per Technical Specification)	UNITS	Quantity for: Construction of 2x40 MVA, 132/33 KV Sub-Station at CDA, CUTTACK	Unit Erection Rate	Total Erection Price
1	2	3	4	5	6=4X5
35	RECEIVING THE TRANSFORMERS AND ITS ACCESSORIES FROM NEAREST OPTCL STORES, DRAGGING AND INSTALLING ON THE PLINTH AND PLACING IN POSITION, ERECTION OF ACCESSORIES OF THE TRANSFORMERS, EART-HING AS PER STANDARD (INCLUDING SUPPLY OF MATERIALS), VACUUM TREATMENT OF THE TANK AND WINDING, OIL FILTRATION (INCLUDING SUPPLY OF VACUUM CUM OIL FILTER MACHINE), SUPPLY & LAYING OF ALL TYPES OF CONTROL & POWER CABLES PERTAINING TO TRANSFORMERS, TESTING AND COMMISSIONING INCLUDING ALL TESTS OF THE OILS AS PER STIPULATION IN THE STANDARD APPROVED TESTING LABORATORY AND AS PER THE INSTRUCTION OF THE ENGINEER IN CHARGE. THIS INCLUDE ALL RELATED WORKS FOR ERECTION (Transformer and its accessories, RTCC Panel etc), TESTING AND COMMISSIONING OF THE POWER TRANSFORMERS. (CONTRACTOR TO ARRANGE POWER SUPPLY FOR FILTRATION AND VACUUM TREATMENT WORKS). IT ALSO INCLUDES SUPPLY OF ALL MATERIALS FOR ERECTION INCLUDING T&P's. <b>1. 132/33 KV 40 MVA: 02 Nos</b>	Nos	2		
36	ERECTION OF PLCC EQUIPMENT SUPPLIED BY OWNER INCLUDING DISMANTLING FROM EXISTING SUBSTATION ( AS PER THE DETAILS SLD GIVEN IN TS) AND TRANSPORTATION AS REQUIRED	LOT	1		
<b>TOTAL of ELECTRICAL WORKS Part-I (A)</b>					
<b>B</b>	<b>CIVIL WORKS</b>				

PART-I, SCHEDULE-2C (FOR SUBSTATION)					
S. No.	DESCRIPTION OF ITEMS	Erection & Civil Works charges IN INR			
	ERECTION, TESTING & COMMISSIONING INCLUDING CIVIL WORKS OF FOLLOWING EQUIPMENTS ALONG WITH CIVIL WORKS (As per Technical Specification)	UNITS	Quantity for: Construction of 2x40 MVA, 132/33 KV Sub-Station at CDA, CUTTACK	Unit Erection Rate	Total Erection Price
1	2	3	4	5	6=4X5
1	<b>Foundations : Design, engineering, supply of all labour, material (Cement-OPC-43 Grade, MS Rod, coarse and fine aggregates (Sand and Metal Chips) etc) for construction of RCC ( 1:1.5:3) &amp; PCC (1:3:6), RCC footings of any depth, pedestal and piling as per requirement including soil investigation, excavation, concreting, shuttering, grouting, underpinning and back filling of foundations etc complete for the following switch yard gantry/ portal structures and equipment support &amp; others as per the technical specification and approved drawings. (RCC RATIO 1:1.5:3). This also includes excavation in all types of soil or rocks, back filling, and disposal of excess earth as per the direction of Engineer In charge.</b>				
1.1	<b>Switch yard gantry/portal structure foundations</b>				
1.1.1	T1S - 132 KV				
1.1.2	T4S - 132KV				
1.1.3	T8S – 33KV				
1.1.4	T9S – 33KV				
1.2	<b>Equipment foundations :</b>				
1.2.1	145 KV, 800-400-200 A, 31.5 KA, 4 CORE SINGLE PHASE CURRENT TRANSFORMER				
1.3	145 KV, 1250A, 31.5KA, ISOLATORS				
1.3.1	S/I WITH OUT EARTH SWITCH				
1.3.2	D/I WITH SINGLE EARTH SWITCH				

<b>PART-I, SCHEDULE-2C (FOR SUBSTATION)</b>					
<b>S. No.</b>	<b>DESCRIPTION OF ITEMS</b>	<b>Erection &amp; Civil Works charges IN INR</b>			
	<b>ERECTION, TESTING &amp; COMMISSIONING INCLUDING CIVIL WORKS OF FOLLOWING EQUIPMENTS ALONG WITH CIVIL WORKS (As per Technical Specification)</b>	<b>UNITS</b>	<b>Quantity for: Construction of 2x40 MVA, 132/33 KV Sub-Station at CDA, CUTTACK</b>	<b>Unit Erection Rate</b>	<b>Total Erection Price</b>
<b>1</b>	<b>2</b>	<b>3</b>	<b>4</b>	<b>5</b>	<b>6=4X5</b>
1.3.3	D/I WITHOUT EARTH SWITCH				
1.4	145 KV,6600pF,3CORE,SINGLE PHASE CAPACITOR VOLTAGE TRANSFORMER				
1.5	120 KV METAL OXIDE SURGE ARRESTOR, 10 KA, Class III				
1.6	145 KV ,2 CORE,SINGLE PHASE,IVT				
1.7	132 KV Bus Post Insulators				
1.8	145KV,3150A,40KA,SF6,CIRCUIT BREAKER WITH SUPPORTING STRUCTURE				
1.9	36 KV,800-400-200,25KA,3CORE SINGLE PHASE CURRENT TRANSFORMER				
1.10	36 KV CLASS NCT FOR POWER TRANSFORMER REF PROTECTION (RATIO 800-400-200 A) & HAVING TWO CORE (PS CLASS) (IN EACH POWER TRANSFORMER 132 KV SIDE: 1 NO, & 33 KV SIDE:1 NO)				
1.11	<b>36 KV,800A,25KA,ISOLATORS</b>				
1.11.1	S/I WITH OUT EARTH SWITCH				
1.11.2	D/I WITH SINGLE EARTH SWITCH				
1.11.3	D/I WITHOUT EARTH SWITCH				
1.12	30 KV, METAL OXIDE SURGE ARRESTOR, 10KA, class II				
1.13	36 KV ,2 CORE,SINGLE PHASE,IVT				
1.14	36KV,1250A,25KA,VACUUM CIRCUIT BREAKER WITH SUPPORTING STRUCTURE				
1.15	33 KV Bus Post Insulators				
1.16	SUB STATION SWITCHYARD BMK,AC CONSOLE & OTHER MARSHALLING BOXES				
1.16.1	BAY MARSHALLING KIOSK (03 Nos 132 kv bay & 04 Nos 33 KV bay)				
1.16.2	SWITCH YARD AC CONSOLE FOR LIGHTING ( 01 Nos 132 kv bay & 01 No in 33KV bay )				

<b>PART-I, SCHEDULE-2C (FOR SUBSTATION)</b>					
<b>S. No.</b>	<b>DESCRIPTION OF ITEMS</b>	<b>Erection &amp; Civil Works charges IN INR</b>			
		<b>UNITS</b>	<b>Quantity for: Construction of 2x40 MVA, 132/33 KV Sub-Station at CDA,CUTTACK</b>	<b>Unit Erection Rate</b>	<b>Total Erection Price</b>
<b>1</b>	<b>2</b>	<b>3</b>	<b>4</b>	<b>5</b>	<b>6=4X5</b>
<b>1.16.3</b>	SWITCH YARD RECEPTACLE BOARD FOR TFR OIL FILTERATION ( 1 No near 132/33 KV power Transformer)				
<b>1.16.4</b>	SWITCH YARD RECEPTACLE BOARD FOR WELDING & OTHER EMERGENCY (01 nos each on 132 & 33 kV bay )				
<b>1.17</b>	EXCAVATION.:This also includes excavation in all types of soil or rocks,back-filling,and disposal of excess earth as per the direction of Engineer In charge.				
<b>1.17.1</b>	Norma Soil(SOFT/LOOSE)	Cum	400		
<b>1.17.2</b>	Hard Soil	Cum	100		
<b>1.17.3</b>	Soft Rock	Cum	100		
<b>1.17.4</b>	Hard Rock required blasting	Cum	50		
<b>1.17.5</b>	Supply of all materials like cement, MS Rod (Supply,Cutting,Bending,Binding (including supply of binding wire) and placing in position of steel rods of different size as per design in the foundation pit as required for the above foundations), all coarse aggregates, fine aggregates and making <b>pile</b> foundations with boring of piles ( <b>pile bore as per required depth, basing on design</b> ) for Switch yard column foundation, Equipment foundation, Marshaling boxes foundation as indicated above and as per requirement, including supply of all materials,labours, de-watering,proper curing of the foundations and T&P as per specification in the RCC :1:1.5:3 (Grade M-20.) including stabilization of bore :- : Pile diameter ( <b>450 MM</b> ) and approximate length of the bore is 10 Mtrs.	mtrs	900		
<b>1.17.6</b>	-DO- Required diameter of the pile boring (375 mm) bore holes for piles (approximate length of the bore is 10 Mtrs)	mtrs	1200		
<b>1.17.7</b>	-DO- Required diameter of the pile boring (300 mm) bore holes for piles (approximate length of the bore is 10 Mtrs)	mtrs	200		

<b>PART-I, SCHEDULE-2C (FOR SUBSTATION)</b>					
<b>S. No.</b>	<b>DESCRIPTION OF ITEMS</b>	<b>Erection &amp; Civil Works charges IN INR</b>			
	<b>ERECTION, TESTING &amp; COMMISSIONING INCLUDING CIVIL WORKS OF FOLLOWING EQUIPMENTS ALONG WITH CIVIL WORKS (As per Technical Specification)</b>	<b>UNITS</b>	<b>Quantity for: Construction of 2x40 MVA, 132/33 KV Sub-Station at CDA, CUTTACK</b>	<b>Unit Erection Rate</b>	<b>Total Erection Price</b>
<b>1</b>	<b>2</b>	<b>3</b>	<b>4</b>	<b>5</b>	<b>6=4X5</b>
<b>1.17.8</b>	-DO- Required diameter of the pile boring (250 mm) bore holes for piles (approximate length of the bore is 10 Mtrs)	mtrs	2500		
<b>1.17.9</b>	Pile riser, cap, tie-beam with RCC: 1:1.5:3 (Grade M-20) ,including supply of all materials like MS Rod(Supply,Cutting,Bending,Binding (including supply of binding wire) and placing in position of steel rods of different size as per design in the foundation pit as required for the above foundations),Cement, coarse and fine aggregates,shuttering and supply of labours, de-watering,proper curing of the foundations/concrete and T&P in line with the Specification and as per direction of Engineer in Charge.	Cum	1050		
<b>1.17.10</b>	Design, Engineering, Providing and laying of plain cement concrete (PCC 1:3:6) of grade M10 with approved quality coarse aggregates (Nominal size 12mm to 20mm) , fine aggregates, cement in column and equipment foundation as blind layer inclusive of labour charges for concrete mixing & curing. This includes supply of all labourers, T&P and dewatering wherever required as per Technical specification and instruction of Engineer In charge.	Cum	50		



<b>PART-I, SCHEDULE-2C (FOR SUBSTATION)</b>					
<b>S. No.</b>	<b>DESCRIPTION OF ITEMS</b>	<b>Erection &amp; Civil Works charges IN INR</b>			
		<b>UNITS</b>	<b>Quantity for: Construction of 2x40 MVA, 132/33 KV Sub-Station at CDA,CUTTACK</b>	<b>Unit Erection Rate</b>	<b>Total Erection Price</b>
<b>1</b>	<b>2</b>	<b>3</b>	<b>4</b>	<b>5</b>	<b>6=4X5</b>
<b>2</b>	<p><b>Cable Trenches:</b> Design, engineering, and construction of RCC cable trenches and all associated works for cable trench and cable trench crossings as per technical specifications and approved drawings and as per direction of the Engineer in Charge.</p> <p>(1) This also includes excavation in all types of soil or rocks,back filling,and disposal of excess earth as per the direction of Engineer In charge.</p> <p>(2) Design, Engineering, Providing and laying of plain cement concrete (PCC 1:3:6) of grade M10 with approved quality coarse aggregates (Nominal size 12mm to 20mm) , fine aggregates, cement in cable trench foundation as blind layer inclusive of labour charges for concrete mixing &amp; curing. This includes supply of all labourers, T&amp;P and dewatering wherever required as per Technical specification and instruction of Engineer In charge.</p> <p>(3) Open cast foundation for the cable trench with RCC: 1:1.5:3 (Grade M-20 Nominal mixing),including supply of Labour all materials like MS Rod,Cement, coarse and fine aggregates,shuttering,cutting,bending,binding of M.S.Rod including supply of binding wire proper curing of the foundations/concrete and T&amp;P in line with the Specification and as per direction of Engineer in Charge.</p> <p>(4) Brickwork with KB brick ,plastering (1:6 Ratio) &amp; curing, wherever required including the supply of labour,material, cement, etc.</p> <p>(5)Supply,fabrication &amp; Fixing of MS Angle(G.I) for cable tray support (as per specification). The cable tray support frame shall be pre fabricated GI angle as per requirement and to be welded with the plate fixed on the trench wall for better rigidity. The plate (6mm) fixed on the wall are also to be welded with the MS rods provided for the trench wall before concreting.</p> <p>(6) Precast of RCC covers (1:1.5:3) and its fixing on the cable trench as per spec and instruction of Engg. In Charge.</p> <p>(7) CABLE TRENCHES INSIDE THE CONTROL ROOM SHALL BE COVERED WITH M.S CHEQUERED PLATE(Duly painted as per instruction of Engg in charge) INCLUDING STANDARD SUPPORT STAND {HD Galvanised (M.S JOIST ,CHANNEL,ANGLE)}.</p>				
<b>2.1</b>	Section 1-1	Mtrs	300		

<b>PART-I, SCHEDULE-2C (FOR SUBSTATION)</b>					
<b>S. No.</b>	<b>DESCRIPTION OF ITEMS</b>	<b>Erection &amp; Civil Works charges IN INR</b>			
		<b>UNITS</b>	<b>Quantity for: Construction of 2x40 MVA, 132/33 KV Sub-Station at CDA,CUTTACK</b>	<b>Unit Erection Rate</b>	<b>Total Erection Price</b>
<b>1</b>	<b>2</b>	<b>3</b>	<b>4</b>	<b>5</b>	<b>6=4X5</b>
2.2	Section 2- 2	Mtrs	200		
2.3	Section 3-3	Mtrs	200		
2.4	Section 4-4	Mtrs	500		
3	<b>Rain water harvesting</b> system as per Technical specification and approval of drawing and as per the direction of the Engineer in charge.	LOT	2		
4	<b>Cable trench crossing</b> :Design,engineering,construction including supply of labour,materials,cement,reinforcement steel,formwork etc,and all associated works for construction of trench crossing as per technical specification and approved drawing.(Road crossing )				
4.1	Section 1-1	Lot	1		
4.2	Section 2- 2	Lot	1		
4.3	Section 3-3	Lot	1		
5	<b>Boundary wall</b> : Soil investigation,Design, engineering,procurement of material,labour including all associated works for construction of boundary-wall along the property line of the sub-station as per technical specification and instruction of the Engineer in Charge.(the size of the bricks shall be 250mm having 1st class kiln burn having compressive strength with 75kg/cm2). This also includes excavation in all types of soil or rocks,backfilling,and disposal of excess earth,Piling etc as per the direction of Engineer In charge.(**APPROXIMATE LENGTH OF THE BOUNDARY WALL IN MTRS) and as per approved drawing.				
5.1	Supply of all materials like cement, steel, all coarse aggregates, fine aggregates and making <b>pile</b> foundations with boring of piles ( <b>pile bore as per required depth, basing on design</b> ) for Boundary wall and as per requirement, including supply of all materials,labours, de-watering,proper curing of the foundations and T&P as per specification in the RCC :1:1.5:3 (Grade M-20.) including stabilization of bore :- Pile diameter ( <b>250 MM</b> ) and approximate length of the bore is 10 Mtrs.	Mtrs	800		

<b>PART-I, SCHEDULE-2C (FOR SUBSTATION)</b>					
<b>S. No.</b>	<b>DESCRIPTION OF ITEMS</b>	<b>Erection &amp; Civil Works charges IN INR</b>			
		<b>UNITS</b>	<b>Quantity for: Construction of 2x40 MVA, 132/33 KV Sub-Station at CDA, CUTTACK</b>	<b>Unit Erection Rate</b>	<b>Total Erection Price</b>
<b>1</b>	<b>2</b>	<b>3</b>	<b>4</b>	<b>5</b>	<b>6=4X5</b>
<b>5.2</b>	<b>Grade Beam Concreting</b> : Design, engineering, supply of all labour, material (Cement-OPC-43 Grade,MS Rod(Supply,Cutting,Bending,Binding (including supply of binding wire), coarse and fine aggregates and construction of PCC (1:3:6) & RCC RATIO 1:1.5:3 as per requirement including excavation, concreting, shuttering, grouting, underpinning and back filling of open cast grade beam concreting etc complete for the boundary walls, as per the technical specification and approved drawings. This also includes excavation in all types of soil or rocks, back filling and disposal of excess earth as per the direction of Engineer In charge.				
<b>5.3</b>	<b>Excavation in all type soil and rocks and back filling (back filling shall be done in layers of 500mm sprinkling of water and compaction thereafter and disposed of excess quantity of excavated soil at suitable place after back filling), &amp; if required for filling the foundation, borrowed earth/murum/sand shall be brought for filling and compaction, including supply of sand, all T&amp;P, labour as required.</b>	Cum	100		
<b>5.4</b>	<b>P.C.C (1:3:6): Lean Concrete Grade M-10 (For blind layer)</b>	Cum	15		
<b>5.5</b>	<b>R.C.C(1:1.5:3): Reinforced Cement Concrete Grade M-20 (For grade beam etc)</b>	Cum	150		
<b>5.6</b>	Brick works including plastering, painting, supply & fixing of "Y" post with barbed wires as per spec & approved drawing(the size of the bricks shall be 250mm having 1st class kiln burn having compressive strength with 75kg/cm2)	Mtrs	640		
<b>6</b>	Contour Survey & Leveling of sub-station and other area and stone pitching works to protect from soil erosion. LEVELLING OF S/S AREA:Providing, neatly dressing up and leveling of switch yard area to a required level as decided by the Engineer in Charge, the work includes removal, clearing of the entire area from vegetation, trees, bushes, uprooting of plants and disposal of surplus earth and unusable material from the site by means of any mechanical transport, with all labours, tools, tackles and plants complete as per approved drawing and specification. This also includes excavation in all type of soils or rocks, and disposal of excess earth or rocks and filling of areas of switch yard by borrowed earth/sand to make the area to a level for construction as per scope.				
<b>6.1</b>	<b>Contour survey of the entire sub-station area including Supply of all labour &amp; T&amp;P by contractor.</b>	<b>SQM</b>	15000		

<b>PART-I, SCHEDULE-2C (FOR SUBSTATION)</b>					
<b>S. No.</b>	<b>DESCRIPTION OF ITEMS</b>	<b>Erection &amp; Civil Works charges IN INR</b>			
		<b>UNITS</b>	<b>Quantity for: Construction of 2x40 MVA, 132/33 KV Sub-Station at CDA,CUTTACK</b>	<b>Unit Erection Rate</b>	<b>Total Erection Price</b>
<b>1</b>	<b>2</b>	<b>3</b>	<b>4</b>	<b>5</b>	<b>6=4X5</b>
<b>6.2</b>	<b>Cutting of sub-station area of the as per the direction of Engineer in Charge.</b>	<b>Cum</b>	400		
<b>6.3</b>	<b>Filling with borrowed earth beyond 30 mtrs lead as per the direction of Engineer in Charge.</b>	<b>Cum</b>	10000		
<b>7</b>	<p>Switch yard buildings: Design, engineering and construction of switch yard buildings including the piling where required, the cost of material, supply of labour, cement, reinforcement- steel, form work and excavation as per the approved drawing and technical specification ( The RCC structure frame should be in the ratio 1:1.5:3).This also includes excavation in all types of soil or rocks,back filling,and disposal of excess earth as per the direction of Engineer In charge. As per approved drawings and specification. <b>CONTROL ROOM BUILDING:(one building):</b></p> <p>A) Area of the Ground floor with portico at front side, stair case to first floor and top of the building. The details of rooms to be provided are as per the Tech spec. B) Area of the first floor. The details of rooms to be provided are as per the Tech spec. Size of Ground floor. Nos./ area of ground floor/area of first floor . 01 No/ Area of Ground Floor : 38 mtrsX11mtrs(418 sq mtrs) / Area of first floor 18mtrsX11mtrs(198 sq mtrs) &amp; portico size 5x6mtr (30sqmtr)</p>				
<b>7.1</b>	RCC volume including MS rods(including column ,Beams and roofs etc) as per technical spec & approved drawings.	Lot	1		
<b>7.2</b>	Brick masonry work in cement sand mortar 1 : 6 with bricks of class designation 75 as per technical spec & approved drawings.	Lot	1		
<b>7.3</b>	Flooring with vitrified tiles with dado in all the rooms,Bath and toilets shall be provided with anti skid ceramic tiles(wall of the same also to be provided with ceramic tiles),Acid proof industrial tiles to be provided on the floor and wall of the battery room as per technical spec & approved drawings.	Lot	1		
<b>7.4</b>	External and internal wall and ceiling paintings as per technical spec mentioned in the civil section. The left over portion of walls and ceiling of Battery room shall be acid proof paints as per specification & approved drawings.	Lot	1		
<b>7.5</b>	Provision of ceiling in the control room area as per specification mentioned in the civil section & approved drawings.	Lot	1		

<b>PART-I, SCHEDULE-2C (FOR SUBSTATION)</b>					
<b>S. No.</b>	<b>DESCRIPTION OF ITEMS</b>	<b>Erection &amp; Civil Works charges IN INR</b>			
		<b>UNITS</b>	<b>Quantity for: Construction of 2x40 MVA, 132/33 KV Sub-Station at CDA,CUTTACK</b>	<b>Unit Erection Rate</b>	<b>Total Erection Price</b>
<b>1</b>	<b>2</b>	<b>3</b>	<b>4</b>	<b>5</b>	<b>6=4X5</b>
7.6	Doors and windows shall be of sliding type with locking facility and shall be of aluminium with glaze of 6mm & windows shall have aluminium grills. As per technical spec & approved drawing.	Lot	1		
7.7	Provision of PHD and other fittings of reputed make,provision of rain water discharge pipes at different locations and etc as per requirement and approved drawing. There shall be septic tank and soak pit of required capacity including complete sewage system as per approved drawing & technical specification & as per instruction of Engg- in-Charge. It includes supply of all types of materials of reputed make, labour etc to complete the work.	Lot	1		
7.8	Internal concealed wiring,fixing of lighting fixtures ,fans and regulators ,exhaust fan,D.C emergency lighting as per spec & approved drawing.	Lot	1		
7.9	Provision of smoke and fire detection system of the building.	Lot	1		
8	<b>Roads:</b> Design, construction of roads and walkways/ shoulders within sub-station( <b>Switch yard area,approach road, control room area, main gate to the switch yard gate etc</b> ) as per specification, layout and approved drawings complete. This also includes excavation in all types of soil or rocks, back filling,and disposal of excess earth as per the direction of Engineer In charge. Provision of drains on both the side of the roads for easy discharge of rain water. (Refer the indicative drawing of s/s layout)				
8.1	3.75 mtrs Bituminus road with shoulder at both the side as per technical specification indicated in the civil section & shall have drain on both side of the road.	Lots	1		
8.2	7 mtrs wide Concrete roads with shoulder as per specification indicated in the civil section. & shall have drain on both side of the road. 7 Mtrs wide road inside the switchyard to be connected to switch yard main gate.	Lots	1		
8.3	7 mtrs wide Bituminus roads with shoulder as per specification indicated in the civil section.( for main and approach roads).Shall have drain on both side of the road.	Lots	1		
9	<b>Drainage system:Collection of rainfall data,</b> Design, construction of storm water drainage scheme, road-culverts, and drains crossing cable trenches etc. as per specification and approved drawing. This also includes excavation in all types of soil or rocks,back filling,and disposal of excess earth as per the direction of Engineer In charge. All the switchyard bays , roads water drainage shall be connected to the main surface drain. As per approved drawing and specification.				

<b>PART-I, SCHEDULE-2C (FOR SUBSTATION)</b>					
<b>S. No.</b>	<b>DESCRIPTION OF ITEMS</b>	<b>Erection &amp; Civil Works charges IN INR</b>			
		<b>UNITS</b>	<b>Quantity for: Construction of 2x40 MVA, 132/33 KV Sub-Station at CDA,CUTTACK</b>	<b>Unit Erection Rate</b>	<b>Total Erection Price</b>
<b>1</b>	<b>2</b>	<b>3</b>	<b>4</b>	<b>5</b>	<b>6=4X5</b>
<b>9.1</b>	Storm water drain	Lots	1		
<b>9.2</b>	Road-culverts, drain crossings	Lots	1		
<b>9.3</b>	Cable trench crossing	Lots	1		
<b>10</b>	<p>Foundations for transformers :Design, engineering, supply of labour, material, equipments and construction of Auto-transformer/Transformer foundation including piling if any, all associated works, rail tracks, jacking pads,anchor block RCC and PCC, miscellaneous structural steel including oil collection pits, MS grating(if required), gravel filling, and other items etc. not mentioned herein, but specifically required for the completion of the work as per technical specification and approved drawing. (Rate shall be inclusive of cement, reinforcement steel, angles,flats and form work etc.)(all cement concrete shall have RCC ratio 1:1.5:3). Transformer RCC foundation and Rail Track should be extended upto the approaching road (However,the height of RCC foundation beyond transformer main plinth area should be same as height of concrete road as per item under 7 mtrs concrete road). This also includes excavation in all types of soil or rocks,back filling,and disposal of excess earth as per the direction of Engineer In charge.</p> <p style="text-align: center;"><b>1. 132/33 KV 40 MVA Transformer (2 Nos)</b></p>				
<b>10.1</b>	<p>12.5/ 20 /40 MVA, 132/ 33kV transformers</p> <p>a) Overall dimension of transformer(appox) Length:7200 mmX Width 6000 mmX Height 6200 mm</p> <p>b) Total weight with oil and tank: 97.5 MT (appox)</p>	Nos	2		
<b>10.2</b>	<p><b>OIL SUMP PIT:</b>Oil collection (from transformers)sump pit with provision of pump(5 HP, with auto level control , including cabling, fixing of control gear )as per CIGRE. As per spec and approved drawing.</p> <p>&gt;Oil capacity of each Transformer in ltrs appox.</p> <p>a) 20/40 MVA,132/33 KV: 26500 ltrs.</p>	Nos	1		

<b>PART-I, SCHEDULE-2C (FOR SUBSTATION)</b>					
<b>S. No.</b>	<b>DESCRIPTION OF ITEMS</b>	<b>Erection &amp; Civil Works charges IN INR</b>			
		<b>UNITS</b>	<b>Quantity for: Construction of 2x40 MVA, 132/33 KV Sub-Station at CDA,CUTTACK</b>	<b>Unit Erection Rate</b>	<b>Total Erection Price</b>
<b>1</b>	<b>2</b>	<b>3</b>	<b>4</b>	<b>5</b>	<b>6=4X5</b>
<b>11</b>	<b>PCC before site surfacing</b> :Providing and supplying all labour, material, equipments etc. required for proper leveling of earth after erection of structures and equipments and proper compaction by using roller of adequate capacity(minimum 3 Ton capacity) with water sprinkling of switch yard area. After proper leveling of the switch yard area (after anti-weed treatment), spreading of plain cement concrete with mixing ratio <b>1:4:8 (M10)</b> and maintaining proper sloping for easy discharge of storm water having concrete thickness of 75 mm. including rolling , dressing, compacting,the area. As per technical specification and approved drawing, and as per the instruction of the <b>Engg-in-Charge</b> . This also includes excavation in all types of soil or rocks,back-filling,and disposal of excess earth as per the direction of <b>Engineer in charge</b> and approved drawing. (Switch yard area)	Lots	1		
<b>12</b>	<b>Metal Spreading:</b> Providing supplying and laying two layers of machine crushed metals (gravel) fill, the first layer after compaction shall make minimum 50 mm thickness coarse/ layer of 20 mm nominal size consolidated/ compacted and (by using roller as specified in the specification).A final layer of 50 mm thickness of machine crushed 20 mm nominal size of metals(gravel) above the first layer of 50 mm thickness and as per the technical specification and instruction of Engineer in charge above the PCC(1:4:8). The total compacted thickness of the metals(20 mm Nominal) 100mm above the PCC.	Lots	1		
<b>13</b>	<b>PROVISION OF PLANTATIONS:</b> Provision of plantation of 100 nos fruit bearing plants and 100 nos decorative plants at different locations, a garden in front of the control room including supply of plants,soil treatment and its plantation including materials,labour and T&P.As per the instruction of Engineer in Charge and specification.	Lot	1		
<b>14</b>	<b>STONE PITCHING &amp; TOE WALL:</b> Stone pitching including making of toe walls by using RR masonry walls respectively. This also includes excavation in all types of soil or rocks,back filling,and disposal of excess earth and supply of materials and labour as per the direction of Engineer In charge and as per approved drawing and specification.				
<b>14.1</b>	<b>Excavation in Soft &amp; Loose Soil</b>	Cum	890		
<b>14.2</b>	<b>P.C.C (1:3:6): Lean Concrete Grade M-10</b>	Cum	90		

<b>PART-I, SCHEDULE-2C (FOR SUBSTATION)</b>					
<b>DESCRIPTION OF ITEMS</b>			<b>Erection &amp; Civil Works charges IN INR</b>		
<b>S. No.</b>	<b>ERECTION, TESTING &amp; COMMISSIONING INCLUDING CIVIL WORKS OF FOLLOWING EQUIPMENTS ALONG WITH CIVIL WORKS (As per Technical Specification)</b>	<b>UNITS</b>	<b>Quantity for: Construction of 2x40 MVA, 132/33 KV Sub-Station at CDA, CUTTACK</b>	<b>Unit Erection Rate</b>	<b>Total Erection Price</b>
<b>1</b>	<b>2</b>	<b>3</b>	<b>4</b>	<b>5</b>	<b>6=4X5</b>
14.3	RR Masonry (1:5)	Cum	500		
14.4	P.C.C (1:2:4): Lean Concrete Grade M-15	Cum	8		
15	Switch yard fencing: Providing and fixing of G.I Goat mesh (2.5 mm dia) fencing( the posts and links shall be of HD Galvanized ) in switch yard and other areas of the substation with a total fence height complete as per specification and approved drawings, and as required under the safety regulation of local, state and central government bodies and as per instruction of the Engineer-in-Charge.(The PCC work for grouting the post shall be 1:2:4 and a continuous Brick masonry work with ratio 1:5 and cement pointing of the joints, for the fencing up to a height from the finished ground level) .This also includes excavation in all types of soil or rocks, back filling,and disposal of excess earth as per the direction of Engineer In charge. The earthing of the fencing as per specification.	MTRS	264		
16	<b>Fire wall:</b> Design, engineering, procurement of labour, material including all associated works for construction of fire-walls as per technical specification and approved drawings(column shall be RCC ratio1:1.5:3 and the walls are of fire resistant bricks).This also includes excavation in all types of soil or rocks,back filling,and disposal of excess earth as per the direction of Engineer In charge. As per approved drawing and specification. Painting of the walls as per direction of the Site In charge	Nos	2		
17	<b>Any other civil work</b> to be included in the schedule by the Bidder if required essential for successful completion of project, including supply of labour, material, cement reinforcement steel, form work etc. Bidder shall also quote the unit rate for the following items of works.(Rate shall be inclusive of supply of labour, material, cement, reinforcement steel, form work etc. )				
17.1	Excavation This also includes excavation in all types of soil or rocks, back filling,and disposal of excess earth as per the direction of Engineer In charge.	Cu.m.	1		
17.2	PCC: M10(1: 3 : 6)	Cu.m.	1		



<b>PART-I, SCHEDULE-2C (FOR SUBSTATION)</b>					
<b>S. No.</b>	<b>DESCRIPTION OF ITEMS</b>	<b>Erection &amp; Civil Works charges IN INR</b>			
		<b>UNITS</b>	<b>Quantity for: Construction of 2x40 MVA, 132/33 KV Sub-Station at CDA,CUTTACK</b>	<b>Unit Erection Rate</b>	<b>Total Erection Price</b>
<b>1</b>	<b>2</b>	<b>3</b>	<b>4</b>	<b>5</b>	<b>6=4X5</b>
17.3	RCC M 15(1:2:4)	Cu.m.	1		
17.4	RCC: M 20(1:1.5:3)	Cu.m.	1		
17.5	Brick masonry work in cement sand mortar 1 : 6 with bricks of class designation 75.	Cu.m.	1		
17.6	12 mm thick plaster in cement sand mortar ( 1 : 6 ).	Sq.m.	1		
17.7	Cutting,bending,binding(supply of binding wires) and fixing of reinforcement(including supply of reinforcement).	M.T.	1		
18	<b>Construction of township/colony</b> (residential quarters) for staff and employees of the employer. Layout, design, survey, leveling, site dressing and clearing of the area, soil investigation, excavation, PCC, RCC, brick work, plastering ,flooring(flooring shall be with vitrified tiles of reputed make with a dado of minimum6 inches),fixing of doors windows and window grills, including all labour material like cement ,sand aggregate, bricks, reinforcements etc with all bought items required for completion of the quarters as per approved construction drawings with all facilities for supply of drinking water. The outer paint shall be applied with weather coat synthetic enamel paint as per the standard practice of application and the inner paint shall be applied with distemper of approved quality as per the instruction and approval of the same by OPTCL. This also includes excavation in all types of soil or rocks,back filling,and disposal of excess earth as per the direction of Engineer In charge. Internal electrical wiring with fixing of light fixtures and fans with electronic regulators and exhaust fans as per technical specification and approved drawing. Construction of over head RCC tank(1000 ltrs capacity one for each quarters), sewerage disposal and connection with main sewerage/ septic tank and soak pit, storm water and surface drainage, culverts, roads, with suitable radius on the curves and its connection with main road the substation, street lighting, internal lighting, internal plumbing and sanitation including internal/external finishing of quarters etc. required for completion of the town ship.				
18.1	"D" type <i>(As per Technical Specification)</i>	Nos.	1		
18.2	"E" type (one no. two storied flat with 2 nos "E" type quarters each on ground floor & 1st floor. <i>(As per Technical Specification)</i>	Nos.	4		

<b>PART-I, SCHEDULE-2C (FOR SUBSTATION)</b>					
<b>S. No.</b>	<b>DESCRIPTION OF ITEMS</b>	<b>Erection &amp; Civil Works charges IN INR</b>			
		<b>UNITS</b>	<b>Quantity for: Construction of 2x40 MVA, 132/33 KV Sub-Station at CDA,CUTTACK</b>	<b>Unit Erection Rate</b>	<b>Total Erection Price</b>
<b>1</b>	<b>2</b>	<b>3</b>	<b>4</b>	<b>5</b>	<b>6=4X5</b>
<b>19</b>	<b>MAIN &amp; SWITCH YARD GATES:</b> Design, engineering, procurement of labour, material including all associated works for construction and fixing of of a main gate and one no. switch yard gates with men gates as per specification and approved drawing. This also includes excavation in all types of soil or rocks,back filling,and disposal of excess earth as per the direction of Engineer In charge. Provision of gate lights (Post top lantern type) on each pillar of the gate. It includes supply & fixing of light fixtures including LED Gate lamp, LV XLPE cables, switchgear etc required to complete works as per specification and approved drawings.	Lot	1		
<b>20</b>	<b>COLOUR CODING, BAY MARKING Etc:</b> Design, engineering, procurement of labour, material including all associated works for the followings. This should be as per direction of site In charge. a)Color coding (red,Yellow & Blue) for equipments,Bus gantry &column of entire switch yard. Good quality weather proof sticker may be used for identification. b)Each bay should be identified with the help of bay marker sign board, suitably grouted. MS sign board with stand to be installed. Proper painting and lettering to be done of the entire switch yard area.	Lot	1		
<b>21</b>	<b>STATION TRANSFORMER:</b> Design, engineering, procurement of labour, material including all associated works for construction of foundation and DP structure for station transformers 33/0.415 KV,315 KVA STN TRANSFORMER as per approved drawing and specification. <i>{33 KV AB Switch (600A),HG Fuse,DP Structure &amp; Angles (duly painted),Channels,Plinth for erection of the transformer, including fixing and laying of (insulators,surge arresters, XLPE armoured power cables 3.5 core 300 sq mm,LT out door kiosk near transformers and other accessories for complete installation of transformer as per standard) and instruction of Engineer In charge. As per the specification and approved drawing. (* REMARKS : FOR SUPPLY OF ALL THE CABLES ,AB Switch etc AS INDICATED ARE COVERED IN THE supply)}</i>	Lot	1		

<b>PART-I, SCHEDULE-2C (FOR SUBSTATION)</b>					
<b>S. No.</b>	<b>DESCRIPTION OF ITEMS</b>	<b>Erection &amp; Civil Works charges IN INR</b>			
		<b>UNITS</b>	<b>Quantity for: Construction of 2x40 MVA, 132/33 KV Sub-Station at CDA,CUTTACK</b>	<b>Unit Erection Rate</b>	<b>Total Erection Price</b>
<b>1</b>	<b>2</b>	<b>3</b>	<b>4</b>	<b>5</b>	<b>6=4X5</b>
<b>22</b>	<b>SECURITY SHED &amp; CUM VISITOR ROOM:</b> Design, engineering, procurement of labour, material including all associated works for construction of Security shed near main gate,watch tower shed at the corners of switch yard as per the approved drawing and instruction of Engineer in charge. This also includes excavation in all types of soil or rocks,back filling,and disposal of excess earth as per the direction of Engineer In charge. Internal electrification including supply of lighting fixtures,fan with regulators and provision of incoming AC supply from the main ACDB/outdoor kiosks installed for street light or colony quarters. Also includes painting of the building (in side and out side) as per recommended for colony building in the specification.				
<b>22.1</b>	<b>SECURITY SHED:</b> The size of the security shed shall be 3.5 mtrsX5mtrs and height of 3.5mtrs RCC roof,brick masonry works,plastering and painting and fixing of MS doors and windows.	Nos	1		
<b>23</b>	<b>BORE WELL &amp; PUMP HOUSE:</b> Design, engineering, procurement of labour, material including all associated works for construction of two nos. bore wells for control room building including switch yard and colony quarters as per specification and approved drawing and instruction of Engineer in charge. This includes supply and fixing and commissioning of two nos 5 HP submersible water pump with starter and other protection. Construction of two nos pump house at ideal location for fixing of the electrical starter units. The pump house be of RCC roof and having walls of Brick masonry and plastering and painting with MS door having locking arrangement. The size of the room shall be 2.5mtrsX2.5 mtrs having height of 3 mtrs. as per approved drawing and specification. There shall be approach road to the pump house. This includes supply of materials,labours and T&P & excavation of all type of soils including rock and disposal of excess materials as per instruction of Engineer In charge Supply & laying of LV XLPE 3.5CX.35 sqmm cable from ACDB to pump house, control gear & earthing of the system etc to complete the scheme as per approved drawing & instruction of Engineer-in charge.	Lot	1		

<b>PART-I, SCHEDULE-2C (FOR SUBSTATION)</b>					
<b>S. No.</b>	<b>DESCRIPTION OF ITEMS</b>	<b>Erection &amp; Civil Works charges IN INR</b>			
		<b>UNITS</b>	<b>Quantity for: Construction of 2x40 MVA, 132/33 KV Sub-Station at CDA,CUTTACK</b>	<b>Unit Erection Rate</b>	<b>Total Erection Price</b>
<b>1</b>	<b>2</b>	<b>3</b>	<b>4</b>	<b>5</b>	<b>6=4X5</b>
<b>24</b>	Substation earth mat Design, engineering, supply{(except the GI Flats,GI Pipe,M.S Rod)(only erection)} inclusive of corrosion protection measures if any,laying of earth mat conductors of Hot dip galvanised flats of size 75X10mm to the approval of Project Manager, excavation, welding/jointing of ground conductors along with risers (a) upto Finished level from the mat size 75X10 mm GI flats & b) from the finished ground level to the top of the structure and equipment shall be with 50X6 mm GI Flats, with back filling and good compaction,grounding driven rods(40 mm MS solid rod for untreated earth pit ,perforated 50 mm Mid GI pipes for treated earth pits(with details of treatment as per IS). The spacing between the earth conductor not more than 5 mtrs (both way) and to be buried at depth of 700mm from the finished ground level. For provision of treated earth pit and untreated earth pit, refer the specification for designing. Provision of water taps inside the switch yard areas and peripheral treated and nu-treated earth pit are required to be provided for watering the treated earth pits. The no. of treated and un-treated earth pits are to be done as per the practice and as indicated in the drawing for different equipments. This is as per approved drawing and specification.				
<b>24.1</b>	Excavation for laying of EARTHING CONDUCTOR (75x10mm for laying (spacing maximum 5m) (GI FLAT)	Lot	1		
<b>24.2</b>	Excavation for putting the EARTHING DEVICE INCLUDING ITS ASSOCI-ATED ACCESSORIES(50 mm heavy duty GI PIPE 3.0 mtrs long for treated earth pit)	Lot	1		
<b>25</b>	STORE SHED:Design, engineering, procurement of labour, material including all associated works for construction of store shed as per specification and approved drawing. This also includes excavation in all types of soil or rocks,back filling,and disposal of excess earth as per the specification,approved drawing and direction of Engineer In charge. One no store shed of floor size 10X10 mtr having brick walls and plastering with RCC roof. The flooring shall be of 75 mm thickness PCC (mix ratio1:2:4) over RR masonry works (as per standard practice of flooring). Provision of adequate nos of MS racks (proper paintings also to be done as per the direction of site in charge) for keeping the spare materials. The height of the shed shall be 4mtrs above the plinth.	Lot	1		

<b>PART-I, SCHEDULE-2C (FOR SUBSTATION)</b>					
<b>S. No.</b>	<b>DESCRIPTION OF ITEMS</b>	<b>Erection &amp; Civil Works charges IN INR</b>			
		<b>UNITS</b>	<b>Quantity for: Construction of 2x40 MVA, 132/33 KV Sub-Station at CDA, CUTTACK</b>	<b>Unit Erection Rate</b>	<b>Total Erection Price</b>
<b>1</b>	<b>2</b>	<b>3</b>	<b>4</b>	<b>5</b>	<b>6=4X5</b>
26	PLATFORM FOR STORING EQUIMENTS:Design, engineering, procurement of labour, material including all associated works for construction of a platform for storing of bushings,Instrument transformers etc, as per specification and approved drawing. This also includes excavation in all types of soil or rocks,back filling,and disposal of excess earth as per the specification,approved drawing and direction of Engineer In charge. One no platform outside the store shed RR masonry (compacted) with PCC at the top for storing the transformer bushings, Instrument transformers, transformer oil drums etc. The floor size of the platform shall be 15mtrX10 mtr with Galvanised Corrugated Sheet (Tata Make) top cover and associated MS supporting structure duly painted.	Lot	1		
27	<b>PROVISION OF RAMP:</b> Design, engineering, procurement of labour, material including all associated works for construction and fixing of Ramp as per specification and approved drawing. This also includes excavation in all types of soil or rocks,back filling,and disposal of excess earth as per the direction of Engineer In charge. Provision of a ramp of adequate size and capable of for loading and unloading of the materials of 5 Ton capacity from the lorry or to the lorry near the store shed. Adequate size of MS frames and RCC (1:1.5:3) based ramps to be used for the said purpose.	Lot	1		
<b>TOTAL of Part-I (B)</b>					
<b>GRAND TOTAL ( ELECTRICAL WORKS + CIVIL WORKS) (A+B)</b>					

- Note: 1** Before filling up rate/amount etc. in the schedules bidders are requested to read carefully the instruction given in Vol-I of Bidding Document.
- 2** Bidders are required to fill up amount in all column except shaded portion.
- 3** Bidders are requested not to leave any column blank. If any column is left blank it shall be considered that amount against those items are included in any other item and the total amount for that item shall be calculated as free of cost (Zero value). No rate shall be furnished/obtained after bid opening (Ref clause no 33.4.1 of INB vol-I) .
- 4** Kindly enclose soft copy of the duly filled schedule in a CD with the priced copy of Bid.

<b>PART-I, SCHEDULE-2C (FOR SUBSTATION)</b>					
<b>DESCRIPTION OF ITEMS</b>			<b>Erection &amp; Civil Works charges IN INR</b>		
<b>S. No.</b>	<b>ERECTION, TESTING &amp; COMMISSIONING INCLUDING CIVIL WORKS OF FOLLOWING EQUIPMENTS ALONG WITH CIVIL WORKS (As per Technical Specification)</b>	<b>UNITS</b>	<b>Quantity for: Construction of 2x40 MVA, 132/33 KV Sub-Station at CDA, CUTTACK</b>	<b>Unit Erection Rate</b>	<b>Total Erection Price</b>
<b>1</b>	<b>2</b>	<b>3</b>	<b>4</b>	<b>5</b>	<b>6=4X5</b>

**5 Bidder has to quote rates excluding service tax (if any), service tax shall be paid/reimbursed as per conditions of Bid Document.**

Date :  
Place :

(Signature) .....  
( Name) .....  
( Designation ) .....  
(Common Seal) .....