



ORISSA POWER TRANSMISSION CORPORATION LIMITED

(A Government of Orissa Undertaking)

Registered Office: Janpath, Bhubaneswar-751022

OFFICE OF THE SENIOR GENERAL MANAGER (CPC)

Telephone No.0674-2541801

Fax No.0674-2542964

CLARIFICATION TO THE TENDER NOTICE NO. 47/2011-12 (PACKAGE-II)

Tender Specification: Sr. G.M, CPC-TENDER-INSULATOR-56/2011-12

REF: SECTION-IV (TECHNICAL SPECIFICATION): CL. No. 5.2: (A) 132 KV LONG ROD INSULATOR:

The above clause may be read as indicated below:-

Sl No.	Type Of String	Size of Long Rod Insulator (mm)/(unit)	Creepage Distance in mm	No of Unit(132KV)	Electromechanical Strength of Insulator(KN)
1	Single Suspension	200 X 1305	4000	1	90
2	Double Suspension	- DO-	- DO-	2	2 X 90
3	Single Tension	205 X 1450	4300	1	120
4	Double Tension	-DO-	-DO-	2	2 X120

Sr. General Manager,CPC

