

**CLARIFICATION TO QUERIES OF DIFFERENT FIRMS AGAINST**

NOTICE INVITING TENDER-NIT NO. 52/2011-12.

Bid Document No. Sr. G.M-CPC-TENDER-PACKAGE- 61-01,61-02 & 61-03 /2011-12

SI No	Name of the Firm / Referred letter	Queries of the Firm	Clarification by OPTCL
1	M/s J.D.Construction, Bhaskarganj -B , Near Muni Samaj, Sahadevkhunta, Balesore. Ref- Lt No JDC/OPTCL/103 Dated 22.10.2011.	In Package No 61-03/2012 consists only substation work. If we want to make a joint venture with other Agency, what type of Technical criteria, is required.	Either the lead partner or the other partner of JV has to qualify the Technical QR for substation in Package No 61-03.
2	M/s Tesla Transformers Ltd, Bhopal Ref- Lt No TTL/HPD-OPTCL/11- 12/400194/236 Dt 15.10.2011	Vol-I (Cl 4.3) – Construction of 132/33kv substation at Somnathpur:- As per SOW the 33kv feeder bay is 03nos but in SLD diagram the feeder bay is 05nos and written is 04nos.	Total no of 33kv bays is 06nos( feeder bay-03, Transformer bay-02, buscoupler-01) which is clearly mentioned in scope of work(Vol-IIA). However, the SLD is an indicative one and prior to bidding, you may visit the site and asses and quote as per Bidding Proposal Sheet.
		Vol-I(5.1.1 & 5.1.2)- Technical criteria for 220kv bay extension- As per QR, the working experience has been require within 10Years but in schedule 11, the experience required 07Years.	Technical criteria for 220kv bay extension is 10 Years.
		Vol I (Clause-6)- Firm for undertaking for piling work as per Annex-XXIV to meet QR- In QR against clause No 5.1.1 & 5.1.2. The piling work not mention in 61-02.	Annexure-XXIV not required as there is no piling work in the package 61-02

SI No	Name of the Firm / Referred letter	Queries of the Firm	Clarification by OPTCL
		Vol-IIA( clause-2.1.1 XIV) – Supply of ACDC system including all distribution board, Battery and charger system, Aux Xmer.- The quantity of Battery and charger in BOQ schedule 2A SS not mention against clause no 28 of 61-02.	Quote as per Bidding proposal sheet.
		Vol IB(BPS contents-17)- EFT form as per sch-14 – Not available	Not Applicable
		BPS clause-10(Mandatory spares as per sch-03)- Sch-03 of spare item available only 61-02 and not available in 61-03	Quote as per Bidding proposal sheet.
		Vol-I(clause 24.3 submission of Bid- The bidder must submit quality data in 03 copies- As per sch-16 BPS check list details of sr no-06, the bidder must submit qualify data in 06 copy of sch-11	Confirm , 03 copies including original.
3	M/s IVRCL, Hyderabad	1) In the SLD for 132kv & 33kv Main bus twin ACSR Moose conductor a as shown and for reserve bus single ACSR Moose conductor is shown. 2) But in BOQ, all the above are mentioned as single ACSR Zebra.	Quote as per Bidding Proposal Sheet, SLD is indicative one.
		3) Details of Event logger for package I & II	Please visit site and asses the details of event logger in existing substation prior to bidding.

SI No	Name of the Firm / Referred letter	Queries of the Firm	Clarification by OPTCL
		4) Details of bus bar protection for package 61-01/2012	Please visit site and asses the details of Bus bar protection in existing substation prior to bidding.
4	M/s S.R.Associates Infrastructure Pvt Ltd, Bhubaneswar.	1. In Vol-IB, for package 61-03, schedule-3 is not enclosed.	Please quote as per Bidding proposal sheet.
		2. Check list (sl 20) is not enclosed.	Not Applicable .
		3. The SLD page 139 and structural net work page 140 appearing in the booklet scope vol-IIA do not tally with the general extension works to be carried out at somnathpur as per details mentioned elsewhere in the specification. The actual sheets pertaining to somnathpur extension works may kindly be furnished to us.	Please refer and follow scope of work vol-IIA, SLD and structural net works are indicative one.