



ORISSA POWER TRANSMISSION CORPORATION LIMITED

(A Government of Odisha Undertaking)

Registered Office: Janpath, Bhubaneswar-751022

Telephone No.0674-2541801

Fax No. 0674-2542964

CORRIGENDUM OF TENDER SPECIFICATION NO.

CGM-CPC-Control & Power Cable-27/2012-13 for procurement of Control & Power Cable.

As Mentioned		To be Read as.	
<u>At Page No-3</u>		<u>At Page No-3</u>	
<i>Description of materials.</i>	<i>Qty. In Kms.</i>	<i>Description of materials.</i>	<i>Qty. In Kms.</i>
(a) 3&1/2 CX95 Sq.mm Power Cable.	30.00	(a) 3&1/2 CX95 Sq.mm Power Cable.	30.00
(b) 3&1/2 CX25 Sq.mm Power Cable.	37.00	(b) 3&1/2 CX25 Sq.mm Power Cable.	37.00
(c) 3CX2.5 Sq.mm control cable.	84.00	(c) 3CX2.5 Sq.mm control cable.	84.00
(d)3CX2.5 Sq.mm control cable.	135.00	(d)4CX2.5 Sq.mm control cable.	135.00
(e)7C X 2.5 Sq.mm control cable.	94.00	(e)7C X 2.5 Sq.mm control cable.	96.00
(f)9C X 2.5 Sq.mm control cable.	63.00	(f)9C X 2.5 Sq.mm control cable.	48.00
(g)12C X 2.5 Sq.mm control cable.	48.00	(g)12C X 2.5 Sq.mm control cable.	63.00
(h)19C X 2.5 Sq.mm control cable	52.00	(h)19C X 2.5 Sq.mm control cable	52.00
<u>At Page-43, Clause-8.2.4 Insulation</u>		<u>At Page-43 Clause No.8.2.4 Insulation</u>	
The insulation shall be of Polyvinyl Chloride (PVC) compound. The 'General Purpose' Type A shall be used for the LV cables and 'Heat Resisting' Type C.		The insulation shall be of Polyvinyl Chloride (PVC) compound should be 'General Purpose' Type A for LV :Power Cable(and 'heat resistant' Type C for Control Cable .	

CHIEF GENERAL MANAGER [CPC]